PROVINCE OF BRITISH COLUMBIA

Ministry of Justice

Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - STRUCTURE

INCIDENT NUMBER: CVE 2013 08 13 05 01

Location of Incident:

106 - 2200 53 RD AVE VERNON BC

of Occupants (At time of fire): 1

of Injured: 0

of Deaths: 0

Total Dollar Loss Estimate: \$ s.22

Related to Wildland Interface Fire: NO

Property Value:

s.22

Content Value: \$ s.22

Total Value at Risk: \$ s.22

Code Name:

Code Description

PROPERTY COMPLEX: 3400 RESIDENTIAL - SINGLE DETACHED

PROPERTY CLASSIFICATION: 3110 YEAR-ROUND USE DWELLING - 1-FAMILY

GENERAL CONSTRUCTION: 2000 PROTECTED COMBUSTIBLE CONSTRUCTION - WOOD PROTECTED BY PLAST

BUILDING HEIGHT: 0010 1 STORY ABOVE GRADE

GROUND FLOOR AREA: 2000 101 TO 500M2 (1077 - 5382FT2)

YEAR OF CONSTRUCTION: 2005 2005

MANUAL FIRE PROTECTION: 7000 NO MANUAL FIRE PROTECTION

OUTSIDE FIRE PROTECTION: 1000 PUBLIC HYDRANT PROTECTION & FIRE DEPARTMENT

SPRINKLER PROTECTION: 7000 NO SPRINKLER PROTECTION

AUTOMATIC FIRE ALARM SYSTE: 1000 NO FIRE ALARM SYSTEM

SMOKE ALARM OPERATION: 6000 ALARM NOT ACTIVATED - UNSUITABLE LOCATION

INITIAL DETECTION: 7000 VISUAL SIGHTING OR OTHER MEANS OF PERSONAL DETECTION (E.G. S

TRANSMISSION OF ALARM: 1000 911

FIRE SERVICE: 3000 COMPOSITE - CAREER & VOLUNTEER/PAID-ON-CALL FIRE DEPARTMENT

INCIDENT: 1000 FIRE - FIRE DEPARTMENT ATTENDED

ACTION TAKEN: 3000 EXTINGUISHED BY FIRE DEPARTMENT

METHOD OF FIRE CONTROL: 4300 38MM/42MM (1 1/2"/1 3/4") HOSE - 2 OR MORE HAND LINES

FIRE ORIGIN, LEVEL: 3000 GROUND FLOOR, GRADE LEVEL OR GRADE TO 3M (10FT)

FIRE ORIGIN, AREA: 7600 EXTERIOR WALL

EXTENT OF FIRE: 6000 EXTENDED BEYOND PROPERTY OF ORIGIN

EXTENT OF DAMAGE: 6000 EXTENDED BEYOND BUILDING OF ORIGIN

IGNITING OBJECT: 5100 PERMANENT ELECTRIC WIRING, CABLE (NON-ALUMINUM) - INCLUDES P

FUEL OR ENERGY: 6000 ELECTRICITY

FORM OF HEAT: 2000 SPARK, ELECTRICAL - INCLUDES ARC, DISCHARGE. (EXCLUDES STATI

MATERIAL FIRST IGNITED: 3000 EXTERIOR WALL COVERING, SURFACE, FINISH - INCLUDES EAVE

ACT OR OMISSION: 4400 ELECTRICAL SHORT CIRCUIT

Investigating Officer

LAFC Badge #

Telephone

ReportDate

SKOLROOD, LAWRIE

250-550-3563

2014-01-20

PROVINCE OF BRITISH COLUMBIA Ministry of Justice Emergency Management BC / Office of the Fire Commissioner FIRE REPORT - STRUCTURE (NARRATIVE)

INCIDENT NUMBER: CVE 2013 08 13 05 01

Remarks:

THE CAUSE OF THIS FIRE WAS AN ELECTRICAL FAILURE IN THE METER BASE FOR THIS DWELLING. DUE TO THE AMOUNT OF DAMAGE, THE CAUSE OF THIS FAILURE AND THE RESULTING ARC FLASH WAS NOT DETERMINED

Investigating Officer SKOLROOD, LAWRIE LAFC Badge #

735

Telephone

ReportDate

250-550-3563

2014-01-20